

Annual Drinking Water Quality Report for 2024
Village of Allegany
106 East Main St. Allegany N.Y. 14706
(Public Water Supply ID# NY0400330)

INTRODUCTION

To comply with State regulations, the Village of Allegany, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact **Randy Chase, Chief Water Operator at (716) 373-1460**. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled village board meetings. The meetings are held on the first Mondays of the month at 4:00 PM or visit our web site at www.allegany.org.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source is groundwater wells: groundwater drawn from three 70-foot deep drilled wells which are located in three different locations in the village. The water is pumped from the wells into a 1 million gallon storage tank. The water is treated with fluoride and disinfected with chlorine as it is transferred to the storage tank. During 2023, our system did not experience any water use restrictions.

In 2003, the NYS DOH completed a source water assessment for our water system, based on available information. Possible and actual threats to the drinking waters sources were evaluated. The source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential contamination of the source water. It does not mean that the water delivered to consumers is, or will become contaminated. See section "ARE THERE CONTAMINANTS IN OUR DRINKING WATER?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

As was mentioned before, our water is derived from three wells. The source water assessment has rated the combined susceptibility to contamination for these wells as; very high from enteric bacteria, enteric viruses and nitrates; high from cations/anions (salts, sulfate), halogenated solvents, metals, other industrial organics, petroleum products and protozoa; and medium-high from herbicides/pesticides. These ratings for the wells are due to their proximity to oil and gas wells, sand and gravel mines, pasture lands and permitted discharge facilities (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state and/or federal government). While the assessment rates our sources as being susceptible to enteric bacteria, please note that our water is disinfected to ensure that the finished water delivered into your home meets New York State's drinking water standards. A copy of this assessment, including a map of the assessment area, can be obtained by contacting us, as noted above.

FACTS AND FIGURES

Our water system serves 2,000 people through 800 service connections in the Village of Allegany and 2,725 through 227 service connections in the Town of Allegany. The total water produced in 2024 was 305 million gallons. The daily average of water treated and pumped into the distribution system to serve Village and Town customers was 830,00 gallons per day. Our highest single day was 1 million gallons. The amount of water delivered to Village and Town customers was 267,438,375 million gallons. This leaves an unaccounted total of 38 million gallons. This water was used to supply wellhouse analyzer monitoring, flush sewer mains, flush hydrants, and fight fires (7 million gallons combined) in the Village. Leakage and unmetered services accounts for the remaining 31 million gallons (10% of the total amount produced) in the Village Boundaries. In 2024, Village water customers were charged \$15.93 per 1,000 gallons of water.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: coliform bacteria, inorganic compounds, nitrate, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA’s Safe Drinking Water Hotline (800-426-4791) or the Cattaraugus County Health Department at (716) 701-3386. Information is also available from the EPA website: <https://www.epa.gov/dwreginfo/drinking-water-regulations>.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Disinfectants							
Chlorine Residual	No	2024	Avg. = .51 (.17 - .85)	mg/l	N/A	MRDL = 4	Water additive used to control microbes.
Inorganic Contaminants							
Barium	No	11/23/21	High = 91.5 (73.3 – 91.5)	ug/l	2,000	MCL = 2,000	Discharge of drilling wastes.
Copper ¹ (Village and Town combined)	No	7/24/24	90 th = 181 (17 - 426)	ug/l	1,300	AL = 1,300	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride- treated	No	2024 Daily	High = 1.1 (0 – 1.1)	mg/l	N/A	MCL = 2.2	Erosion of natural deposits; water additive that promotes strong teeth.
Lead ² (Village and Town combined)	No	7/24/24	90 th = 4.5 (<1 – 10.6)	ug/l	0	AL = 15	Corrosion of household plumbing; erosion of natural deposits.
Nickel	No	11/23/21	High = .979 (.683 - .979)	ug/l	n/a	Not established	Nickel enters ground water and surface water by dissolution of rocks and soils; from atmospheric fall out; from biological decay and from waste disposal.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Nitrate	No	8/6/24 – 10/9/24	High = 5.4 (2.3 – 5.4)	mg/l	10	MCL = 10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Sodium – Well #2	No	8/10/23	23.1	mg/l	N/A	See Health Effects ³	Naturally occurring; road salt; water softeners; animal waste.
Disinfection By-Products							
Haloacetic Acids	No	8/8/24	LRAA = >1.00 (ND – 1.68)	ug/l	N/A	LRAA = 60	By-product of drinking water disinfection needed to kill harmful organisms.
Total Trihalomethanes	No	8/8/24	LRAA = 2.60 (2.24 – 20.6)	ug/l	N/A	MCL = 80	By-product of drinking water disinfection needed to kill harmful organisms.
Synthetic Organic Contaminants including Pesticides and Herbicides							
Perfluorobutane-sulfonic acid (PFBS)	No	11/7/24	3.83 - 5.34	ng/l	N/A	MCL = N/A	Released into the environment from widespread use in commercial and industrial applications.
Perfluorohexanoic acid (PFHxA)	No	11/7/24	ND - 1.88	ng/l	N/A	MCL = N/A	Released into the environment from widespread use in commercial and industrial applications.

Notes:

- 1 - The level presented represents the 90th percentile of the 20 sites tested (Village and Town combined). A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, twenty samples were collected at your water system and the 90th percentile value was the third highest value, 181 ug/l. The action level for copper was not exceeded at any of the sites tested.
- 2 - The level presented, 4.5 ug/l, represents the 90th percentile of the twenty samples collected. None of the sites exceeded the action level of 15 ug/l.
- 3 - Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets.

Definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Nanograms per liter (ng/l): Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt).

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations, but we have learned through our testing that some contaminants have been detected; however, these contaminants were detected below New York State requirements.

Although nitrate was detected below the MCL, it was detected at 5.4 mg/L in Well #1 and 5.2 mg/L in Well #3, which is greater than one-half of the MCL. Therefore, we are required to present the following information on nitrate in drinking water:

“Nitrate in drinking water at levels above 10 mg/l is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.”

Additionally, we are required to provide the following standard information on lead in drinking water.

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. The Village of Allegany is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and take steps to reduce your family’s risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, and making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or a galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact the Village of Allegany at 716-373-1460. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2024, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

INFORMATION ON LEAD SERVICE LINE INVENTORY

A Lead Service Line (LSL) is defined as any portion of pipe that is made of lead which connects the water main to the building inlet. An LSL may be owned by the water system, owned by the property owner, or both. The inventory includes both potable and non-potable SLs within a system. In accordance with the federal Lead and Copper Rule Revisions (LCRR) our system has prepared a lead service line inventory and have made it publicly accessible by request at the Village of Allegany Clerks Office; 106 E. Main Street Allegany NY 14706 or by email at apapasergi@allegany.org.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

INFORMATION ON FLUORIDE ADDITION

Our system is one of the many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at a properly controlled level. To ensure that the fluoride supplement in your water provides optimal dental protection, we monitor fluoride levels on a daily basis to make sure fluoride is maintained at a target level of 0.7 mg/l. None of the monitoring results showed fluoride levels that approach the 2.2 mg/l MCL for fluoride.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- Saving water saves energy and some of the costs associated with both of these necessities of life;
- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes. If it moved, you have a leak.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this past year. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.